

## **Stark**

- Media center Sheet rocking and re-caulking
  - Project to bid out combined with work at Newfield, Hart, and Stark
- Installed temporary flashing on all windows. Further temporary work will be performed this summer to prevent water intrusion
- More extensive long term exterior brick envelope project being planned for next summer.
  - Involves replacing windows and disposing of PCBs.
  - A/E firm still determining extent of repairs needed.
    - Building envelope study to be performed by Silver Pettrucelli at Stark, Hart and Toquam.
- Waterproofing of planters to be done this summer. Drains will also be installed so water does not pool up in planters.
- Infrared Roof Scan
  - [Roof Model](#)
  - [Roof Report](#)

If you have any additional questions, please email  
[Moldtaskforce@stamfordct.gov](mailto:Moldtaskforce@stamfordct.gov)