

KT Murphy Elementary School

Summary of Work: March 13, 2019

Active spreadsheet of work being conducted in areas of concern posted on City website under school page. Please [CLICK HERE](#) to view the active sheet.

- **Skylights**- Will be a summer project, glass will need to be ordered soon.
- **Plaster Ceilings 11/12 Corridor**- Will be a summer project, [tests](#) and [assessment](#) posted on website. Budget number will be finalized in the next couple of days.
- **Auditorium**- Duct work insulated up to stage.
- **Room 39**- Ceiling tiles were removed and sheet rock was replaced. Two pipes from boy's bathroom above were the cause of the leak. Pipes were fixed. BoE to paint.
- **Silver Petrucelli**- conducted a full site visit. [Report](#) posted on website.
- **Electrical Work**- BoE to conduct electrical work around ceiling tiles this week so they may be replaced.