



Legend

- THERMOGRAM
- NIC** NOT IN CONTRACT
- SUSPECTED WET INSULATION
- DRAIN

Areas: Total of All Roofs (in approximate square feet)

Square Footage of Roof Inspected:	29,634
Square Footage of Suspected Wet Area:	181
Percentage of Suspected Wet Area:	<1%

INFRA-RED ROOF MOISTURE ANALYSIS		
 INFRARED • ELD FUSION • NUCLEAR P: (800) 879-3964 • F: 866-906-3922 • email: info@iranalyzers.com NATIONWIDE SERVICE	VIKING CONSTRUCTION BRIDGEPORT, CT KT MURPHY ELEMENTARY STAMFORD, CT	SCALE: 3/32"=1'-0"
		DATE: 05-16-19
		PAGE: 1 OF 1
		DRAWN BY: DMR JOB#: 19231X09

