

PHASE CONTRAST MICROSCOPY AREA AIR SAMPLING DATA SHEET

Tighe & Bond

Project Number: 28-2087-033 Date: 11/14/19
 Project Name: Stamford - Mold Task Force
 Contractor: AAIS License Number: 017
 Project Monitor: Randy Taylor Project Monitor License Number: 743
 Scope of Work: Roof H Replacement - Removal of Perimeter Flashing

Sample ID Number	Sample Location	Project Activity	Sample Time		Sample Duration (Min.)	Flow Rate (Liters/Min.)			Total Volume (Liters)	Fiber Count (Fib/Field)	Concentration (Fibers/CC)
			On	Off		Pre	Post	Avg.			
111419RT-01	Field Blank	Background	-	-	-	-	-	-	-	0/100	<0.002
-02	Sealed Blank		-	-	-	-	-	-	-	0/100	<0.002
-03	Stage		0726	1303	337	7.0	7.0	7.0	2359	7/100	<0.002
-03	Duplicate		-	-	-	-	-	-	2359	6/100	<0.002

Samples Collected By: Randy Taylor Date: 11/14/19 Time:
 Samples Analyzed By: Randy Taylor Date: 11/14/19 Time:
 Analyst AAR Number: 9450
 Lab Drop-Off Lab Name: Turnaround Time: Special Instructions: Date/Time:
 Samples Relinquished By: Date/Time: Samples Received By: Date/Time:
 Results Reviewed By: