

PHASE CONTRAST MICROSCOPY AREA AIR SAMPLING DATA SHEET

Tighe & Bond

Project Name: Stamford - Mold Task Force - Springfield **Project Number:** 28-2087-033
Project Location: 1127 Hope Street, Stamford **Sampling Date:** 11/19/19
Work Area Designation: Roof H **Project Monitor Name:** Randy Taylor
Microscope #: 3 **Project Monitor License #:** 743

Sample #	Sample Location	Project Activity	Sample Time (minutes)		Flow Rate (Liters/Minute)		Average Flow Rate (Liters/Min)	Total Volume (Liters)	Fiber Count (Fib/Field)	Concentration (Fibers/CC)
			On	Off	Pre	Post				
11919RT-01	Field Blank	Backgrounds	-	-	-	-	-	-	0/100	<0.002
-02	Sealed Blank		-	-	-	-	-	-	0/100	<0.002
-03	Stage		0649	0955	7.0	7.0	1302		3/100	<0.002
-04	Hall by Main Office		0651	0957	7.0	7.0	1302		2/100	<0.002
-05	Stage		0956	1254	7.0	7.0	1246		6/100	0.0023
-06	Hall by Main Office		0958	1256	7.0	7.0	1246		10/100	0.0039
-05	Duplicate		-	-	-	-	1246		8/100	0.0031

Chain of Custody and Sample Receiving Log

Samples Analyzed By:		Date:	11/20/19	Time:		AAR#	9450
Sample Collected By:	Randy Taylor	Date:	11/19/19	Time:			
Samples Relinquished By:	Randy Taylor	Date:		Time:			
Samples Received By:		Date:		Time:			
Results Reviewed By:		Date:		Time:			

1302 x 10220.7

1246 x 9781.1