

PHASE CONTRAST MICROSCOPY AREA AIR SAMPLING DATA SHEET

Tighe & Bond

Project Number: 28-20870330	Date: 9-28-19
Project Name: Springfield School 1	
Contractor: MAIS	License Number:
Project Monitor: Bob Robbins	Project Monitor License Number: 617
Scope of Work: Floor Contactor 015 RM 102 - Floor Tile / Mastic / Physical Sub Floor	

Sample ID Number	Sample Location	Project Activity	Sample Time		Sample Duration (Min.)	Flow Rate			Volume (Liters)	Fiber Count (Fib/Field)	Concentration (Fibers/CC)
			On	Off		Pre	Post	Avg.			
928BH-01	Blank	Rem/FAC								0/100	0.0
-02	Blank									0/100	0.0
-03	015 Peron		617	1030	253	5.6	5.6	5.6	1,417	8/100	0.0028
-04	Con. 015 RM 102 - IC		1100	1223	83	15.0	15.0	15.0	1,245	2/100	0.0022
-05			1101	1224	83	15.0	15.0	15.0	1,245	1/100	0.0022
-06			1102	1225	83	15.0	15.0	15.0	1,245	1/100	0.0022
-07			1103	1226	83	15.0	15.0	15.0	1,245	1/100	0.0022
-08			1104	1227	83	15.0	15.0	15.0	1,245	3/100	0.0022
dup-08										2/100	0.0022

FAC = Final Air Clearance, IC = Inside Containment

Samples Collected By: Bob Robbins	Date: 9-28-19	Time:
Samples Analyzed By: BA	Date: 9-28-19	Time:
Analyst AAR Number: 9028		
Lab Drop-Off Lab Name:	Turnaround Time:	Special Instructions:
Samples Relinquished By:	Date/Time:	Date/Time:
Results Reviewed By:		