

Toquam

- [Summer work](#) - Toquam
- Clerestory windows and Roof replacement for $\frac{3}{4}$ of the roof this summer
 - Coordination meeting with Silktown Roof, City of Stamford, Bismark Construction and Tighe & Bond took place on June 4th to discuss scheduling for work this summer.
 - Bismark to conduct work on sheetrock surrounding clerestory windows 1 week before silktown roof replaces the window.
 - Work starts day after school ends (6/19)
- Pipe insulation
 - Temporary insulation to be installed to tie in with air handler replacement project down the line.
- TEMPORARY patching to be done at portables
- Exhaust fan switches
 - The exhaust fans themselves are new and in fine condition
 - Electrical contractor can replace switches to help extend life for control system.
 - Bismark to replace one switch and see if there is a difference.
- Building envelope study to be performed by Silver Pettrucelli at Stark, Hart and Toquam.
- [Asbestos air samples](#) taken on 6/8
 - All samples bellow Clean Air Standard.
- Infra-red Rood Analyzers
 - [Roof Scan](#)
 - [Roof Report](#)

If you have any additional questions, please email
Moldtaskforce@stamfordct.gov