

PHASE CONTRAST MICROSCOPY AREA AIR SAMPLING DATA SHEET

Tighe & Bond

Project Number: 28-2087-033

Date: 06/08/19

Project Name: Stamford - Mold Task Force - Tognesi ES.

Contractor: AHS

License Number: 017

Project Monitor: Randy Taylor

Project Monitor License Number: 743

Scope of Work: Drywall / Taping Compound Ceiling

Sample ID Number	Sample Location	Project Activity	Sample Time		Sample Duration (Min.)	Flow Rate			Fiber Count (Fib/Field)	Concentration (Fibers/CC)
			On	Off		Pre	Post	Avg.		
060819RT-01	Field Blank	Background/Clumps	—	—	—	—	—	—	0/100	<0.002
-02	Sealed Blank	—	—	—	—	—	—	—	0/100	<0.002
-03	Recess	Background	0825	0949	84	10.0	10.0	10.0	8/100	0.0046
-04	Containment - A wall (F)	Clamp	0956	1127	91	14.9	14.9	14.9	1/100	<0.002
-05	—	—	0957	1128	91	14.9	14.9	14.9	2/100	<0.002
-06	—	—	0958	1129	91	14.9	14.9	14.9	1/100	<0.002
-07	—	—	0959	1130	91	14.9	14.9	14.9	1/100	<0.002
-08	—	—	1000	1131	91	14.9	14.9	14.9	3/100	<0.002
-09	Duplicate	—	—	—	—	—	—	—	1/100	<0.002

Samples Collected By:

Randy Taylor

Date: 6/8/19

Time:

Samples Analyzed By:

Randy Taylor

Date: 6/8/19

Time:

Analyst AAR Number:

9450

Lab Drop-Off Lab Name:

Turnaround Time:

Special Instructions:

Samples Relinquished By:

Date/Time:

Samples Received By:

Date/Time:

Results Reviewed By:

213 Court Street • Middletown, CT 06457 • Tel 860.704.4760

• Fax 860.704.4775

8406 6594 1355.96 10643.51