



Legend	
	THERMOGRAM
	SUSPECTED WET INSULATION
	DRAIN

Areas: Total of All Roofs (in approximate square feet)	
Square Footage of Roof Inspected:	68,251
Square Footage of Suspected Wet Area:	1,359
Percentage of Suspected Wet Area:	2.0%

INFRA-RED ROOF MOISTURE ANALYSIS

IR ANALYZERS
Vector Mapping
 INFRARED • ELD FUSION • NUCLEAR
 P: (802) 879-2064 • F: 866-806-3522 • email: info@iranalyzers.com
 NATIONWIDE SERVICE

VIKING CONSTRUCTION
 BRIDGEPORT, CT
 SCOFIELD MAGNET MIDDLE SCHOOL
 STAMFORD, CT

SCALE:	1/16"=1'-0"
DATE:	06-26-19
PAGE:	1 OF 1
DRAWN BY:	DMR
JOB#:	19231X17

