



ARCHITECTURE INTERIOR DESIGN LANDSCAPE ARCHITECTURE ENGINEERING

October 9, 2023

Mr. Chad Armstrong
Assistant Fire Marshall (FM 102)
888 Washington Blvd. 7th fl
Stamford, CT 06901

Re: 900 Long Ridge Road BKV Group responses to Fire Marshall Comments

Dear Mr. Armstrong,

This letter is written in response to comments received in an August 10, 2023, email for the 900 Long Ridge Road project. The received comments and are italicized responses are below. Please contact us should you have any questions.

- Each Building is required to have (2) Fire Department Connections (FDC)
 - a) *BKV Response: Two separate FDC connections will be provided for each building.*
- If a Fire Command Center is required by code, The Fire Command Center/remote key access locations at the buildings entry shall be coordinated with your office.
 - a) *BKV Response: Buildings are not high-rise and would not require a Fire Command Center. Knox box key access locations will be coordinated with your office as part of the building permit drawing process.*
- Standpipes are required within 200ft of any Unit.
 - a) *BKV Response: Acknowledged. Standpipes will be provided to be within 200ft max length of any unit.*

Sincerely,

A handwritten signature in black ink, appearing to read 'John Treiber', with a long horizontal flourish extending to the right.

John Treiber AIA
BKV Group