

May 31, 2024

Mr. Chad Armstrong
Assistant Fire Marshal
Stamford Fire Department
City of Stamford
888 Washington Boulevard
Stamford, CT 06901

RE: 800 Long Ridge Road – Long Ridge Road LLC
Zoning Application No. 223-28

Dear Mr. Armstrong,

On behalf of Long Ridge Road LLC we offer the following responses & revisions that have been made to the site plans per your review of the project.

- 1) A water holding tank is not required for the project due to the existing flows and pressures being adequate for fire suppression. Please refer to e-mail from Bill Buckley, P.E. to you sent Wednesday May 29, 2024 at 4:22 PM for further details.
- 2) Sheets C-3.3 and C-3.4 depict the Fire Department Connections (labeled FDC on each of the buildings).
- 3) Sheets C-3.3 and C-3.4 depict a fire hydrant within 100' of the Fire Department Connections as well as the other four fire hydrants required for a total of five hydrants.
- 4) There is a 24' wide paved driveway provided adjacent to each of the hydrants to provide you with adequate access. This is also labeled on sheets C-3.3 and C-3.4 of the plan set.

Please feel free to contact us if you have any further questions.

Sincerely,

CIVIL 1



Brian J. Baker, P.E.



Cc: William Buckley, P.E.
Lisa L. Fienberg, Esquire
John D Freeman, Esquire.

T 203 266 0778
F 203 266 4759

Cornerstone
Professional Park
Suite D-101
13 Sherman Hill Road
Woodbury, CT 06798
info@CIVIL1.com
www.CIVIL1.com