

MOLD TASK FORCE

11/21/18 Notes

Westover

- School in process of being winterized- BOE in charge of work
- Unit ventilator manufacturer and Johnson Controls on-site to examine 6 unit ventilators – expect detailed report about findings week of 12/3/18
- Custodians to continue to maintain school
- BOE staff to coordinate moving of additional items from Westover, including unused rugs, cabinets and furniture

One Elmcroft

- HVAC Test and Balance work scheduled
- Engineering Bureau recalibrated and charged CO2 sensors throughout building for monitoring
- Tighe & Bond working on AHERA inspection/report to be completed no later than December 13, 2018

School Programing

- Continuing to address needs of teachers and faculty

Other School Sites

Mold Task Force

- General work flow created for remediation efforts
- Contacted forensic consultant

KT Murphy

- Work Plan and Map reviewed and posted to website
- Coordinate work flow for 11/23/18 with principal/AAIS/trades
- Room 20 steam pipe work coordinate and started by BOE trades

Stark

- Hygienist follow-up site visit – Additional Swab Test samples taken
- Additional briefing with Hygienist to discuss areas of concern and potential work plan
- Coordinated site visit for 11/26/18 at 4 pm with Hygienist and private developer to assess workflow
- Initial Assessment posted to website
- Initial Swab Test Results posted to website

Rippowam/Apples

- Initial Swab Test results reviewed and posted to website

Westhill

- Coordinated site visit for 11/26/18 at 5 pm with Hygienist to coordinate workflow

Communication

- Next Mold Task Force public meeting scheduled for 11/28/18
- City social media accounts used to promote Mold Task Force Meeting

Website

- Posted minutes from 11/16/18 through 11/20/18 – we apologize for the delay