

## Davenport

- Full school cleaning performed over April break. Ceiling tile removal, cleaning of mold.
- Extensive work performed in rooms 28/29 to determine underlying causes of water intrusion.
- Classroom construction for 15 classrooms will be performed over the summer, full scope of work has been created by BBS.
  - Install a vapor barrier
    - Help with condensation issues that have led to mold growth in classrooms.
- Roofing repair project this summer- Gottfried
  - Around 100,000
  - Should add 5-7 years
- HVAC- Tucker Mechanical
  - RTU (Roof Top Unit) Repairs
    - Plan for capital project within next five years
  - Heat Exchangers
    - Cracked- replaced as soon as possible
  - Exhaust Fans
    - replace 15 non-working fans
- Site Drainage- This summer